



材料及工程實驗室-台北

試驗報告

報告號碼: HV-08-00191X-1  
 頁數: 1 OF 1  
 日期: 97年02月04日

委託單位: 交泰興有限公司  
 供料商: 交泰興有限公司  
 地址: 台北市研究院路二段54巷30號1樓  
 樣品名稱: KEIM-Optil 室內塗料  
 採(送)樣者: 交泰興有限公司(王學聖)  
 送樣日期: 97年01月14日  
 試驗日期: 97年01月14日~97年02月04日  
 備註: 以上資料由送驗人員提供(試驗日期除外)

試驗結果:


測試項目	CAS NO.	測試方法	測試結果	檢測極限	單位
甲醛	000050-00-0	本測試參考 DIN 53315, 以高效液相層析儀/二極體陣列偵測器(HPLC/DAD)檢測之	N.D.	3.0	ppm(mg/kg)

測試項目	單位	測試方法	方法偵測極限	測試結果
可塑劑	---	---	---	---
鄰苯二甲酸二(2-乙基己基)酯 (DEHP)	ppm	CHROMATOGRAPHIA VOL.47,NO.784,1998	30	n.d.
鄰苯二甲酸二異癸酯 (DIDP)	ppm	CHROMATOGRAPHIA VOL.47,NO.784,1998	30	n.d.
鄰苯二甲酸二正辛酯 (DNOP)	ppm	CHROMATOGRAPHIA VOL.47,NO.784,1998	30	n.d.
鄰苯二甲酸二丁酯 (DBP)	ppm	CHROMATOGRAPHIA VOL.47,NO.784,1998	30	n.d.
鄰苯二甲酸丁酯苯甲酯 (BBP)	ppm	CHROMATOGRAPHIA VOL.47,NO.784,1998	30	n.d.
鄰苯二甲酸二異壬酯 (DINP)	ppm	CHROMATOGRAPHIA VOL.47,NO.784,1998	30	n.d.

註: 1. 低於方法偵測極限之測定值以 "N.D." 表示。

2. 本試驗報告取代 HV-08-00191X, 原試驗報告作廢, 報告修改日期: 97年03月03日。

--- 0 0 0 ---



規範資料檢閱參考, 合格之判定以委託單位實際要求為準。

張 繼 子

報告簽署人

TW 5704723

This Test Report is issued by the Company subject to its General Conditions of Service printed overleaf or available on request and accessible at [www.sgs.com](http://www.sgs.com). Attention is drawn to the limitations of liability, indemnification and jurisdictional issues defined therein. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested. This test report cannot be reproduced, except in full, without prior written permission of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this report is unlawful and offenders may be prosecuted to the fullest extent of the law. 此報告係依據本公司訂定之適用服務條款所製作發放, 請注意此條款列印於背面, 亦可在 [www.sgs.com](http://www.sgs.com) 中查閱。將本公司之義務、免費、管轄權聲明規範之。除非另有說明, 此報告結果僅對檢驗之樣品負責。本報告未經本公司書面許可, 不可部份複製。對本報告內容或外觀之任何未經授權之變更、偽造、竄改皆屬非法, 違犯者將會被依法追訴。